



Bwrdd Iechyd
Addysgu Powys
Powys Teaching
Health Board

Information Governance Team
Hafren Ward
Bronllys Hospital
Bronllys
Brecon
Powys LD3 0LY
Email: Powys.FOI@wales.nhs.uk
Tel: 01686 252159/01874 442071

Our ref: IG/FOI/24.R.275

2 August 2024

Sent via email to: [REDACTED]

Dear [REDACTED]

Request under the Freedom of Information Act 2000

I write further to your request for information, which was received on 15 July 2024, to confirm, in accordance with S.1(1)(a) of the Freedom of Information Act 2000, that Powys Teaching Health Board (PTHB) does hold the information that you require.

For ease of reference your request is set out below and my response follows.

Your Freedom of Information (FOI) Request:

Can you please confirm that the latest projects at Machynlleth have been completed to the correct HTM and are compliant! Also Ystradgynlais project confirming this has been completed to the HTM including the electrical installation and medical gas pipeline systems!

Powys Response:

Regarding Machynlleth Hospital, I can confirm that the scope of work for the project included the renewal of water and ventilation services and was designed by an independently appointed professional Design Team. There are no piped medical gases to the front of the building, however, a new gas manifold room was created as part of the project to meet appropriate regulations and to serve the wider hospital building. The work was designed and installed in accordance with Health Technical Memorandum (HTM) 04-01 safe water in healthcare premises, Welsh Health Technical Memorandum (WHTM) 03-01 specialised ventilation in healthcare premises and HTM 02-01 medical gas pipeline systems, unless formally agreed as an appropriate derogation. NHS Wales Shared Services Partnership, Specialist Estates Services, Authorising Engineers, undertook independent checks of the project pre-handover. Any subsequent defects which may become apparent will be addressed in line with the 'defects liability period' process if applicable.

Pencadlys
Tŷ Glasbury, Ysbyty Bronllys,
Aberhonddu, Powys LD3 0LU
Ffôn: 01874 711661



Headquarters
Glasbury House, Bronllys Hospital
Brecon, Powys LD3 0LU
Tel: 01874 711661

Rydym yn croesawu gohebiaeth Gymraeg
Bwrdd Iechyd Addysgu Powys yw enw gweithred Bwrdd Iechyd Lleol
Addysgu Powys



We welcome correspondence in Welsh
Powys Teaching Health Board is the operational name of
Powys Teaching Local Health Board

Regarding Ystradgynlais Hospital, I can confirm all projects are designed to appropriate guidance, where practicable within existing buildings, and to meet relevant HTM requirements unless formally agreed as an acceptable derogation. Any subsequent defects which may become apparent will be addressed in line with the 'defects liability period' process, if applicable.

Under the terms of the Health Board's Freedom of Information procedure, individuals seeking access to recorded information held by the Health Board are entitled to request an internal review of the handling of their requests. If you would like to complain about the Health Board's handling of your request, please contact us directly at the address below or register your complaint via powysfoi.foi@wales.nhs.uk

If after Internal Review you remain dissatisfied you are also entitled to refer the matter to the information commissioner at the Information Commissioner's Office (Wales), 2nd Floor, Churchill House, Churchill Way, Cardiff, CF10 2HH. Telephone Number: 0330 414 6421.

Yours sincerely



Pete Hopgood
Executive Director of Finance, Capital & Support Services/ Deputy
Chief Executive Officer

Rydym yn croesawu derbyn gohebiaeth yng Nghymraeg. Byddwn yn ateb y fath ohebiaeth yng Nghymraeg ac ni fydd hyn yn arwain at oedi.

We welcome receiving correspondence in Welsh. We will reply to such correspondence in Welsh and this will not lead to a delay.